


**LEGEND:**

- ACCESS TRACK - MAIN BESS COMPOUND TRACK (6m WIDE)
- OPTION AREA / SITE BOUNDARY LINE
- NEW SECURITY FENCE LINE
- CCTV
- CCTV EXCLUSION
- BESS CLEARANCE TO FENCE LINE (+6.1m TO FENCE)
- BATTERY UNIT (BESS)
- POWER CONVERSION SYSTEM (PCS)
- WATER TANK & PUMP
- WATER TANK INCLUSION ZONE (OD Ø180m)
- RENDEZVOUS POINT (RVP) - MIN. 250m<sup>2</sup>

**NOTES:**

1. THIS DRAWING AND THE WORKS DEPICTED ARE COPYRIGHT OF SSE RENEWABLES LTD. UNAUTHORISED REPRODUCTION OR MODIFICATION INFRINGES COPYRIGHT.
2. INDICATIVE PURPOSES ONLY. NOT FOR CONSTRUCTION.
3. DO NOT SCALE FROM THIS DRAWING.
4. DIMENSIONS SHALL BE CONFIRMED ON SITE.
5. SUBJECT TO TOPOGRAPHY, GROUND INVESTIGATION, AND OTHER RELEVANT SURVEYS.
6. SUBJECT TO DETAILED ELECTRICAL DESIGN.
7. SUBJECT TO DRAINAGE STRATEGY AND DESIGN.
8. FINAL CONFIGURATION SUBJECT TO DETAILED DESIGN AND EQUIPMENT MANUFACTURER APPROVAL.
9. THIS DRAWING SHALL NOT BE USED TO SPECIFY ANY EQUIPMENT.

Scale 1:1000



**Figure 2.9**  
**Typical Battery Storage Layout**